

TOSHIBA	Toshiba Transmission & Distribution Systems (India) Pvt.Ltd. Distribution Transformers Division	Engineering
		Unit-10

GUARANTEED TECHNICAL PARTICULARS THREE PHASE DISTRIBUTION TRANSFORMER					
Tender No : 09573-3		Customer :- KKM POWER OY, FINLAND Tender No :- 233449			
kVA : 200	kV :20.5/0.41	Phase : 3	Freq. : 50Hz	Cooling : ONAN	Doc No: EGT 38070
Sl. No.	Description	UNIT	200 kVA		
1)	Make		Toshiba Transmission & Distribution Systems (India) Pvt. Ltd		
2)	Type		Hermitically Sealed		
3)	Phases	No.	Three		
4)	Rating	kVA	200 kVA		
5)	Voltage:				
	HV	V	20500		
	LV	V	410		
6)	Tapping		Not Applicable		
7)	Frequency	Hz	50		
8)	Vector Group		Dyn11		
9)	Insulation Level				
	HV	kV peak	125		
	LV	kV peak	Not Applicable		
10)	Power Frequency Level				
	HV	kV rms	50		
	LV	kV rms	3		
11)	Winding material		Aluminum		
12)	Core Material		CRGO		
13)	Temperature Rise:				
	Oil	°C	60		
	Winding	°C	65		
14)	Losses				
	No Load Losses at rated Voltage and Frequency	Watt	250 (MAX)-A0		
	Load Losses at 75 °C	Watt	2750 (MAX)-Ck		
15)	Impedance Voltage	%	4% (+/- IEC Tolerance Applicable)		
16)	Percentage Resistance	%	1.38		

TOSHIBA		Toshiba Transmission & Distribution Systems (India) Pvt.Ltd. Distribution Transformers Division		Engineering
				Unit-10
17)	Regulation at:			
	Full Load UPF	%	1.45	
	Full Load 0.8 PF	%	3.38	
18)	Efficiency at 0.8 PF:			
	Full Load	%	98.16	
	¾ Full Load	%	98.52	
	½ Full Load	%	98.84	
19)	Terminal Arrangement:			
	HV			Bare Bushings-Porcelain
	LV			Bare Bushings-Porcelain
20)	Overall Dimensions:			
	Length	mm	1030	
	Width	mm	780	
	Height	mm	1300(*)	
21)	Overall Weight			
	Total Weight	Kg.	1045	
22)	Noise Level	LwA dB (A)	45.3	

Note:

1. Actual overall dimensions and weights are subjected to +/-10% Tolerance, provided that the tolerance is not exceeded the maximum value defined.
2. All the efficiencies and regulations are calculated at the nominal values of NLL, LL AT 75 Deg C and % Z at 75 Deg C.